

Record of Water Taking

Report Date: 2014.04.03 Period: 2014.03.01 - 2014.03.31
 Kagiano Power Corporation Permit #: 4727-7VPPMV
 P.O. Box 192 Source: Kagiano River Surface Water
 Heron Bay, Ontario P0T 1R0 Location: Latitude 49.11.26, Longitude 86.07

MASL - Meters Above Sea Level : M - Meters : Sec - Seconds : kW - Kilowatts

Date	Weir Slots Open	Average Daily Water Level MASL	Average Daily Flow through Falls m ³ /sec	Maximum Rate of Taking Through Turbines m ³ /min	Total Amount of Taking Through Turbines m ³	Average Station kW kW	RECORDS SEEN FOR DAY	MAX kW
3/1/2014	14	na	na	92.15	126,705.95	614	0/0	642.6
3/2/2014	14	na	na	91.13	120,498.68	584	0/0	635.5
3/3/2014	14	na	na	85.48	114,811.78	556	0/0	596.1
3/4/2014	14	na	na	85.72	112,746.82	546	0/0	597.8
3/5/2014	14	na	na	84.84	111,094.85	538	0/0	591.6
3/6/2014	14	na	na	78.63	106,345.44	515	0/0	548.3
3/7/2014	14	550.36	0.020	91.85	116,463.74	564	112/96	
3/8/2014	14	550.36	0.020	86.05	116,739.07	565	96/96	
3/9/2014	14	550.36	0.023	86.83	109,993.54	533	91/96	
3/10/2014	14	550.36	0.020	89.54	119,630.02	579	96/96	
3/11/2014	14	550.36	0.020	88.84	121,419.65	588	96/96	
3/12/2014	14	550.36	0.026	86.57	118,804.03	575	96/96	
3/13/2014	14	550.36	0.023	83.80	114,261.12	553	96/96	
3/14/2014	14	550.36	0.021	85.24	114,949.44	557	95/96	
3/15/2014	14	550.36	0.021	82.38	114,949.44	557	96/96	
3/16/2014	14	550.36	0.024	80.55	109,855.87	532	96/96	
3/17/2014	14	550.36	0.025	76.69	106,001.28	513	96/96	
3/18/2014	14	550.36	0.024	79.20	105,175.30	509	96/96	
3/19/2014	14	550.36	0.016	76.82	104,624.64	507	95/96	
3/20/2014	14	550.36	0.021	74.87	103,798.66	503	96/96	
3/21/2014	14	550.36	0.024	77.06	100,632.38	487	96/96	
3/22/2014	14	550.36	0.019	74.58	98,842.75	479	96/96	
3/23/2014	14	550.36	0.026	71.05	94,712.83	459	96/96	
3/24/2014	14	550.36	0.015	67.13	90,995.90	441	96/96	
3/25/2014	14	550.36	0.016	67.66	88,930.94	431	95/96	
3/26/2014	14	550.36	0.027	65.03	85,214.02	413	96/96	
3/27/2014	14	550.36	0.018	64.04	86,590.66	419	96/96	
3/28/2014	14	550.35	0.007	65.62	86,452.99	419	96/96	
3/29/2014	14	550.36	0.030	63.76	83,286.72	403	96/96	
3/30/2014	14	550.36	0.022	63.43	82,460.74	399	96/96	
3/31/2014	14	550.36	0.021	62.18	83,837.38	406	96/96	

SERVER FAILURE MARCH 1ST - MARCH 6TH (DATA RECORDING INTERRUPTED)
 POWER READINGS TAKEN FROM MANITOUWADGE SUBSTATION
 SUBSTATION READINGS / 1.015 TO ACCOUNT FOR TRANSMISSION LOSSES.