

# Record of Water Taking

Report Date: 2017-10-01      Period: 2017.09.01 - 2017.09.30  
 Kagiano Power Corporation      Permit #: 4727-7VPPMV  
 P.O. Box 192      Source: Kagiano River Surface Water  
 Heron Bay, Ontario POT 1R0      Location: Latitude 49.11.26, Longitude 86.07

MASL - Meters Above Sea Level : M - Meters : Sec - Seconds : kW - Kilowatts

Date	Weir Slots Open	Average Daily Water Level	Average Daily Flow through Wier Slots m <sup>3</sup> /sec	Maximum Rate of Taking Through Turbines m <sup>3</sup> /min	Total Amount of Taking Through Turbines m <sup>3</sup>	Average Station kW	RECORDS SEEN FOR DAY
2017-09-01	14	550.52	>1.309	0.00	0.00	0	97/96
2017-09-02	14	550.51	>1.309	0.00	0.00	0	96/96
2017-09-03	14	550.52	>1.309	0.00	0.00	0	96/96
2017-09-04	14	550.52	>1.309	0.00	0.00	0	96/96
2017-09-05	14	550.52	>1.309	0.00	0.00	0	96/96
2017-09-06	14	550.52	>1.309	0.00	0.00	0	96/96
2017-09-07	14	549.31	DEWATERED	0.00	0.00	0	96/96
2017-09-08	14	548.29	DEWATERED	0.00	0.00	0	96/96
2017-09-09	14	548.29	DEWATERED	0.00	0.00	0	96/96
2017-09-10	14	548.28	DEWATERED	0.00	0.00	0	96/96
2017-09-11	14	548.29	DEWATERED	0.00	0.00	0	96/96
2017-09-12	14	548.29	DEWATERED	0.00	0.00	0	96/96
2017-09-13	14	548.30	DEWATERED	0.00	0.00	0	96/96
2017-09-14	14	548.30	DEWATERED	0.00	0.00	0	96/96
2017-09-15	14	548.31	DEWATERED	0.00	0.00	0	96/96
2017-09-16	14	548.31	DEWATERED	0.00	0.00	0	96/96
2017-09-17	14	548.30	DEWATERED	0.00	0.00	0	96/96
2017-09-18	14	548.30	DEWATERED	0.00	0.00	0	96/96
2017-09-19	14	548.30	DEWATERED	0.00	0.00	0	96/96
2017-09-20	14	548.30	DEWATERED	0.00	0.00	0	96/96
2017-09-21	14	548.30	DEWATERED	0.00	0.00	0	96/96
2017-09-22	14	548.31	DEWATERED	0.00	0.00	0	96/96
2017-09-23	14	548.30	DEWATERED	0.00	0.00	0	96/96
2017-09-24	14	548.30	DEWATERED	0.00	0.00	0	96/96
2017-09-25	14	548.29	DEWATERED	0.00	0.00	0	96/96
2017-09-26	14	548.29	DEWATERED	0.00	0.00	0	96/96
2017-09-27	14	548.29	DEWATERED	0.00	0.00	0	96/96
2017-09-28	14	548.29	DEWATERED	0.00	0.00	0	96/96
2017-09-29	14	548.29	DEWATERED	0.00	0.00	0	96/96
2017-09-30	14	548.30	DEWATERED	0.00	0.00	0	96/96

GENERATOR CLEANING. STOP LOGS WERE INSTALLED.