

Record of Water Taking

Report Date: 2018-03-02 Period: 2018.02.01 - 2018.02.28
 Kagiano Power Corporation Permit #: 4727-7VPPMV
 P.O. Box 192 Source: Kagiano River Surface Water
 Heron Bay, Ontario POT 1R0 Location: Latitude 49.11.26, Longitude 86.07

MASL - Meters Above Sea Level : M - Meters : Sec - Seconds : kW - Kilowatts

Date	Weir Slots Open	Average Daily Water Level	Average Daily Flow through Wier Slots m ³ /sec	Maximum Rate of Taking Through Turbines m ³ /min	Total Amount of Taking Through Turbines m ³	Average Station kW	RECORDS SEEN FOR DAY
2/1/2018	14	550.35	0.000	158.89	221,914.37	1,075	97/96
2/2/2018	14	550.35	0.000	153.72	216,407.81	1,048	96/96
2/3/2018	14	550.35	0.000	150.00	209,799.94	1,016	96/96
2/4/2018	14	550.35	0.000	149.42	204,293.38	989	96/96
2/5/2018	14	550.35	0.000	154.44	196,584.19	952	96/96
2/6/2018	14	550.35	0.000	142.32	191,903.62	929	96/96
2/7/2018	14	550.34	0.000	140.53	188,599.68	913	96/96
2/8/2018	14	550.35	0.000	137.23	183,919.10	891	96/96
2/9/2018	14	550.34	0.000	134.74	180,339.84	873	96/96
2/10/2018	14	550.42	0.461	123.75	175,383.94	849	96/96
2/11/2018	14	550.42	0.430	171.51	176,485.25	855	96/96
2/12/2018	14	550.35	0.000	129.58	175,934.59	852	96/96
2/13/2018	14	550.35	0.000	128.16	168,776.06	817	96/96
2/14/2018	14	550.35	0.000	119.67	169,326.72	820	96/96
2/15/2018	14	550.35	0.000	122.06	170,152.70	824	96/96
2/16/2018	14	550.35	0.000	125.33	164,370.82	796	96/96
2/17/2018	14	550.35	0.000	114.35	157,762.94	764	96/96
2/18/2018	14	550.34	0.000	114.25	155,560.32	753	96/96
2/19/2018	14	550.35	0.000	113.46	155,835.65	755	96/96
2/20/2018	14	550.36	0.021	166.34	154,183.68	747	96/96
2/21/2018	14	550.34	0.000	119.61	150,053.76	727	96/96
2/22/2018	14	550.35	0.007	509.64	140,967.94	683	77/96
2/23/2018	14	550.34	0.000	105.44	146,474.50	709	96/96
2/24/2018	14	550.35	0.000	106.13	146,474.50	709	96/96
2/25/2018	14	550.35	0.000	111.68	151,981.06	736	96/96
2/26/2018	14	550.35	0.000	109.67	152,807.04	740	96/96
2/27/2018	14	550.35	0.000	108.55	151,155.07	732	96/96
2/28/2018	14	550.35	0.000	106.82	148677.12	720	96/96

Broken Insulator Replaced February 22nd - Shutdown for approximately 5 Hours