

Record of Water Taking

Report Date: 2018-04-03 Period: 2018.03.01 - 2018.03.31
 Kagiano Power Corporation Permit #: 4727-7VPPMV
 P.O. Box 192 Source: Kagiano River Surface Water
 Heron Bay, Ontario POT 1R0 Location: Latitude 49.11.26, Longitude 86.07

MASL - Meters Above Sea Level : M - Meters : Sec - Seconds : kW - Kilowatts

Date	Weir Slots Open	Average Daily Water Level	Average Daily Flow through Wier Slots m ³ /sec	Maximum Rate of Taking Through Turbines m ³ /min	Total Amount of Taking Through Turbines m ³	Average Station kW	RECORDS SEEN FOR DAY
3/1/2018	14	550.35	0.000	105.10	144,547.20	700	97/96
3/2/2018	14	550.35	0.000	102.59	137,664.00	667	96/96
3/3/2018	14	550.35	0.000	117.67	131,606.78	637	96/96
3/4/2018	14	550.35	0.000	93.58	127,476.86	617	96/96
3/5/2018	14	550.35	0.000	89.34	123,897.60	600	96/96
3/6/2018	14	550.35	0.000	87.59	119,217.02	577	96/96
3/7/2018	14	550.35	0.000	84.91	117,014.40	567	96/96
3/8/2018	14	550.35	0.000	118.96	115,637.76	560	96/96
3/9/2018	14	550.34	0.000	81.62	112,609.15	545	96/96
3/10/2018	14	550.44	0.581	293.83	100,219.39	485	96/96
3/11/2018	14	550.35	0.000	75.74	99,393.41	481	92/96
3/12/2018	14	550.37	0.051	138.02	104,899.97	508	96/96
3/13/2018	14	550.35	0.000	85.32	107,102.59	519	96/96
3/14/2018	14	550.35	0.000	76.20	102,422.02	496	96/96
3/15/2018	14	550.35	0.000	75.87	101,871.36	493	97/96
3/16/2018	14	550.35	0.000	72.16	97,190.78	471	96/96
3/17/2018	14	550.35	0.000	70.42	95,814.14	464	96/96
3/18/2018	14	550.35	0.000	106.42	91,408.90	443	96/96
3/19/2018	14	550.40	0.244	356.78	74,338.56	360	79/96
3/20/2018	14	550.40	0.278	166.77	66,354.05	321	91/96
3/21/2018	14	550.35	0.000	63.33	82,873.73	401	96/96
3/22/2018	14	550.35	0.000	60.60	81,497.09	395	96/96
3/23/2018	14	550.35	0.000	66.82	79,019.14	383	96/96
3/24/2018	14	550.34	0.000	74.51	75,990.53	368	96/96
3/25/2018	14	550.35	0.000	54.62	72,411.26	351	96/96
3/26/2018	14	550.35	0.000	53.96	70,483.97	341	96/96
3/27/2018	14	550.34	0.000	53.90	73,787.90	357	96/96
3/28/2018	14	550.34	0.000	53.82	73237.25	355	96/96
3/29/2018	14	550.35	0.007	125.60	76265.86	369	103/96
3/30/2018	14	550.35	0.000	53.69	70,483.97	341	96/96
3/31/2018	14	550.35	0.000	53.63	68,006.02	329	99/96

March 10th - Units not properly set into auto-mode and headpond rose to 550.44

March 19th - 20th - Electrical Relay Testing PSS

March 29th - Restart RSView multiple times for sync programming