

# Record of Water Taking

Report Date: 2020-10-05

Period: 2020.09.01 - 2020.09.30

Kagiano Power Corporation

Permit #: 4727-7VPPMV

P.O. Box 192

Source: Kagiano River Surface Water

Heron Bay, Ontario POT 1R0

Location: Latitude 49.11.26, Longitude 86.07

MASL - Meters Above Sea Level : M - Meters : Sec - Seconds : kW - Kilowatts

Date	Weir Slots Open	Average Daily Water Level	Average Daily Flow through Wier Slots m <sup>3</sup> /sec	Maximum Rate of Taking Through Turbines m <sup>3</sup> /min	Total Amount of Taking Through Turbines m <sup>3</sup>	Average Station kW kW
9/1/2020	14	548.65	0.000	0.00	0.00	0
9/2/2020	14	548.65	0.000	0.00	0.00	0
9/3/2020	14	548.65	0.000	0.00	0.00	0
9/4/2020	14	548.65	0.000	0.00	0.00	0
9/5/2020	14	550.50	1.246	64.75	18,446.98	89
9/6/2020	14	550.49	1.157	124.97	36,067.97	175
9/7/2020	14	550.54	>1.309	127.51	4,680.58	23
9/8/2020	14	550.51	>1.309	51.19	28,909.44	140
9/9/2020	14	550.53	>1.309	51.84	7,984.51	39
9/10/2020	14	550.54	>1.309	0.00	0.00	0
9/11/2020	14	550.54	>1.309	0.00	0.00	0
9/12/2020	14	550.54	>1.309	0.00	0.00	0
9/13/2020	14	550.54	>1.309	0.00	0.00	0
9/14/2020	14	550.53	>1.309	0.00	0.00	0
9/15/2020	14	550.53	>1.309	0.00	0.00	0
9/16/2020	14	550.53	>1.309	0.00	0.00	0
9/17/2020	14	550.53	>1.309	0.00	0.00	0
9/18/2020	14	550.53	>1.309	0.00	0.00	0
9/19/2020	14	550.53	>1.309	0.00	0.00	0
9/20/2020	14	550.53	>1.309	0.00	0.00	0
9/21/2020	14			0.00	0.00	0
9/22/2020	14			0.00	0.00	0
9/23/2020	14			0.00	0.00	0
9/24/2020	14	Bearing Maintenance. Hydro Outage, Tree on Transmission Line Near Manitouwadge		0.00	0.00	0
9/25/2020	14			0.00	0.00	0
9/26/2020	14			0.00	0.00	0
9/27/2020	14			0.00	0.00	0
9/28/2020	14			0.00	0.00	0
9/29/2020	14	550.53	>1.309	0.00	0.00	0
9/30/2020	14	550.53	>1.309	60.47	2,753.28	13