

Record of Water Taking

Report Date: 2021-09-05

Period: 2021.08.01 - 2021.08.31

Kagiano Power Corporation

Permit #: 4727-7VPPMV

P.O. Box 192

Source: Kagiano River Surface Water

Heron Bay, Ontario POT 1R0

Location: Latitude 49.11.26, Longitude 86.07

MASL - Meters Above Sea Level : M - Meters : Sec - Seconds : kW - Kilowatts

| Date | Weir Slots Open | Average Daily Water Level | Average Daily Flow through Wier Slots m ³ /sec | Maximum Rate of Taking Through Turbines m ³ /min | Total Amount of Taking Through Turbines m ³ | Average Station kW kW |
|-----------|-----------------|---------------------------|--|--|---|--------------------------|
| 8/1/2021 | 14 | | NO STATION POWER - HYDRO SWITCHING ISSUE | | | |
| 8/2/2021 | 14 | 550.51 | >1.309 | 178.96 | 51,486.34 | 249 |
| 8/3/2021 | 14 | 550.50 | 1.257 | 94.82 | 134,360.06 | 651 |
| 8/4/2021 | 14 | 550.50 | 1.282 | 94.26 | 119,217.02 | 577 |
| 8/5/2021 | 14 | 550.50 | 1.271 | 80.03 | 110,406.53 | 535 |
| 8/6/2021 | 14 | 550.50 | 1.273 | 108.05 | 142,069.25 | 688 |
| 8/7/2021 | 14 | 550.49 | 1.232 | 103.26 | 134,360.06 | 651 |
| 8/8/2021 | 14 | 550.50 | >1.309 | 162.62 | 113,985.79 | 552 |
| 8/9/2021 | 14 | 550.50 | 1.280 | 80.50 | 109,305.22 | 529 |
| 8/10/2021 | 14 | 550.50 | 1.254 | 74.58 | 98,842.75 | 479 |
| 8/11/2021 | 14 | 550.50 | 1.300 | 67.67 | 88,655.62 | 429 |
| 8/12/2021 | 14 | 550.50 | 1.282 | 65.53 | 84,525.70 | 409 |
| 8/13/2021 | 14 | 550.50 | 1.265 | 58.05 | 79,569.79 | 385 |
| 8/14/2021 | 14 | 550.50 | 1.253 | 54.82 | 70,483.97 | 341 |
| 8/15/2021 | 14 | 550.50 | 1.289 | 48.45 | 55,340.93 | 268 |
| 8/16/2021 | 14 | 550.50 | 1.250 | 40.08 | 50,935.68 | 247 |
| 8/17/2021 | 14 | 550.50 | 1.277 | 31.91 | 43,226.50 | 209 |
| 8/18/2021 | 14 | 550.50 | 1.274 | 27.99 | 37,995.26 | 184 |
| 8/19/2021 | 14 | 550.53 | >1.309 | 27.62 | 15,418.37 | 75 |
| 8/20/2021 | 14 | 550.55 | >1.309 | 0.00 | 0.00 | 0 |
| 8/21/2021 | 14 | 550.55 | >1.309 | 0.00 | 0.00 | 0 |
| 8/22/2021 | 14 | 550.54 | >1.309 | 79.96 | 6,607.87 | 32 |
| 8/23/2021 | 14 | 550.54 | >1.309 | 36.98 | 5,231.23 | 25 |
| 8/24/2021 | 14 | 550.55 | >1.309 | 38.76 | 3,579.26 | 17 |
| 8/25/2021 | 14 | 550.54 | >1.309 | 39.13 | 6,883.20 | 33 |
| 8/26/2021 | 14 | 550.54 | >1.309 | 38.32 | 5,781.89 | 28 |
| 8/27/2021 | 14 | 550.55 | >1.309 | 0.00 | 0.00 | 0 |
| 8/28/2021 | 14 | 550.54 | >1.309 | 0.00 | 0.00 | 0 |
| 8/29/2021 | 14 | 550.54 | >1.309 | 0.00 | 0.00 | 0 |
| 8/30/2021 | 14 | 550.54 | >1.309 | 38.57 | 2,202.62 | 11 |
| 8/31/2021 | 14 | 550.54 | >1.309 | 0.00 | 0.00 | 0 |